

Micropollutant removal by advanced oxidation of microfiltered secondary effluent for water reuse

Christopher P James^a, Eve Germain^a and Simon Judd^{b*}

^aThames Water R&D, Innovation Centre, Island Road, Reading, Berks RG2 0RP, UK

^bCranfield Water Science Institute, Cranfield University, Cranfield, Beds MK43 0AL, UK

*corresponding author, s.j.judd@cranfield.ac.uk. +44 1234 758310

Abstract

The removal of micropollutants (MPs) from secondary municipal wastewater by an advanced oxidation process (AOP) based on UV irradiation combined with hydrogen peroxide (UV/H₂O₂) has been assessed through pilot-scale experiments incorporating microfiltration (MF) and reverse osmosis (RO). Initial tests employed low concentrations of a range of key emerging contaminants of concern, subsequently focusing on the highly recalcitrant compound metaldehyde (MA), and the water quality varied by blending MF and RO permeate.

Under optimum H₂O₂ and lamp power conditions, AOP achieved significant removal (>99%) of N-nitrosodimethylamine (NDMA) and endocrine disrupting compounds (EDCs) for all waters. Pesticide removal, in particular metaldehyde, atrazine and 2, 4 5-Trichlorophenoxyacetic acid, was dependent on water transmittance (UVT), and levels of TOC and other hydroxyl radical (·OH) scavengers. Further analysis of MA removal showed UVT, hydraulic retention time and H₂O₂ dose to be influential parameters in determining degradation as a function of UV dose.

A cost assessment revealed energy consumption to account for 65% of operating expenditure with lamp replacement contributing 25%. A comparison of three unit process sequences, based on MF, RO, AOP and activated carbon (AC), revealed MF-RO-AOP to be the most cost effective provided management of the RO concentrate stream incurred no significant cost. Results demonstrated AOPs to satisfactorily reduce levels of the more challenging recalcitrant MPs to meet stringent water quality standards for wastewater reuse, but that practical limitations exist and the cost penalty significant.

Keywords: Advanced oxidation; Wastewater reuse; Micropollutants; Metaldehyde; Operating cost.

1 Introduction

Over the past 20 years, there has been increased awareness of the incidence of certain micropollutants (MPs) in the environment and a concomitant increase in the study of their fate and removal by water treatment technologies. This is particularly germane to recovered and reused wastewater, which demands implementation of advanced treatment technologies to attain water of a quality comparable to treated raw waters with respect to the MP levels.

MPs can cause potentially adverse health effects at concentrations in the milligram/nanogram per litre range (Holm, 2011). They may originate from natural or anthropogenic sources, such as industry, agriculture and domestic households. Environmental quality

standards for several organic MPs that may be released into surface waters have been promulgated via regulations such as the European Water Framework Directive (WFD) (EC, 2000). However, there are several other emerging chemicals of concern that are currently unregulated and not monitored, particularly in wastewater effluents. Specifically, the difficulty in effectively managing and reliably treating diffuse sources of pollution poses a significant challenge to wastewater reclamation, especially if intended for human consumption.

Research into removal or fate of MPs has mainly focused on organic compounds often classified as disinfection by-products (DBPs), pharmaceuticals, pesticides, and endocrine disrupting compounds (EDCs). EDCs are widespread in the environment and consist of natural oestrogens (estrone (E1) and 17 β -estradiol (E2)) along with synthetic xenoestrogens (17 α -ethynylestradiol), phthalates and many more, known to affect/interfere with the action of hormones in the endocrine system (Hotchkiss *et al.*, 2008). Sewage effluents have been identified as being a major source of natural estrogenic chemicals in the aquatic environment (Desbrow *et al.*, 1996). Research conducted over the past 15-20 years has highlighted the limited removal capability of conventional wastewater treatment systems to levels that are deemed acceptable.

The use and type of pesticides for wide-ranging applications within the agricultural sector has developed significantly over the past 50 years, and these can readily contaminate raw drinking water sources through run-off. Regulatory limits for pesticide levels in EU drinking waters are 0.1 $\mu\text{g L}^{-1}$ for an individual pesticide and 0.5 $\mu\text{g L}^{-1}$ in total. Among those of concern in drinking waters are atrazine and, most recently, metaldehyde (MA). The latter has been shown to be widely detected in UK water sources (Water UK, 2009) and is not readily removed by conventional water treatment technologies (Autin *et al.*, 2012).

Advanced oxidation processes (AOPs), characterised by the generation of highly reactive, non-selective hydroxyl radicals ($\cdot\text{OH}$), offer a promising alternative to conventional treatment for removing organic constituents in contaminated waters. The UV/H₂O₂ process is amongst the most studied AOP and reported to be effective at degrading recalcitrant MPs such as NDMA (Poussade *et al.*, 2009) and various pharmaceuticals and EDCs (Benotti *et al.*, 2009; Snyder *et al.*, 2007) for indirect potable reuse (IPR) and, in the case of surface water treatment generally, metaldehyde (Autin *et al.*, 2013). Such a process installed downstream of the membrane filtration step of an IPR scheme to remove traces of compounds permeating the RO membrane (Royce *et al.*, 2010) can potentially achieve full mineralisation of MPs (Matilainen and Sillanpää, 2010), whereas reverse osmosis (RO) leaves MPs unchanged in the waste stream thus demanding further management. However, both RO and AOPs are energy and chemically intensive and thus incur a significant cost. Whilst previous studies of AOPs at bench scale have elucidated degradation mechanisms and H₂O₂ dosing requirements (or hydroxyl rate constants) for MP removal (Sanches *et al.*, 2010; Rosario-Ortiz *et al.*, 2010; Katsoyiannis *et al.*, 2011; Baeza and Knappe, 2011), representative costs and performance from larger scale demonstration against real waters have not been quantified.

This study aims to determine both the effectiveness and cost of a UV/H₂O₂ process for treating MPs of emerging concern, and the most highly recalcitrant of these in particular MA, which currently presents a significant challenge to the water industry. Impacts of key parameters, specifically feedwater transmittance, are assessed and process costs compared with those of other candidate processes recently demonstrated on the same large pilot scale.

2 Materials and methods

2.1 Pilot plant and chemical reagents

The pilot plant (Fig. 1), details of which are provided elsewhere (Raffin *et al.*, 2011), treated 600 m³ d⁻¹ of final effluent from a conventional activated sludge (CAS)-based wastewater treatment works. The process consisted of a pre-filter, microfiltration (MF), reverse osmosis (RO) and an advanced oxidation process (AOP), based on a combination of UV irradiation and H₂O₂ dosing (UV/H₂O₂), downstream of the MF (AOP1) and the RO (AOP2).

Each AOP comprised a flow-through UV reactor (Trojan UVPhoxTM, Model 12AL30) equipped with 12 low-pressure/high-output (LP/HO) amalgam lamps with nominal output power from the lamps varies from 60 to 100%. AOP1 reactor was fitted with an automatic sleeve wiping and clean-in-place (CIP) system, the latter using citric acid for iron fouling mitigation or scaling on the quartz sleeves (i.e. fouling).. H₂O₂ was dosed upstream of both UV reactors with static mixers in-line. UV transmittance (at 254 nm), intensity and power were monitored online for each reactor, along with temperature, and independent flowmeters fitted to each stream. Selected MPs (Table 3) were dosed at concentrations generally between 0.2 and 2 µg L⁻¹ into the feed via glass ampoules and/or pipetted from solutions of the compounds dissolved in water/acetone, the latter adding up 15% to the organic carbon but assumed to be inert under the AOP operating conditions employed, based on previous studies (Hernandez *et al.*, 2002). All MPs were of an analytical grade and provided by Sigma Aldrich, with the exception of the EDC compounds (*E1*, *E2* and *EE2*) which were from QMX Laboratories (Essex, UK).




Figure 1. Pilot plant schematic

2.2 Experimental procedure

Feed water quality was varied by testing either the MF, RO or an equal blend of the two permeate streams (Table 1). MPs were then dosed at concentrations based on those typically arising in secondary wastewater, as identified in the literature (Lundstrom *et al.*, 2010; Martin Ruel *et al.*, 2011) and regulatory guidelines (WSR, 2010), or else constrained by their limit of detection as advised by the laboratory (Thames Water Analytical Laboratories, Reading) to allow % removal values to be accurately calculated. Operating conditions for each AOP stream (Table 2) were determined from the optimum UV lamp input power and H₂O₂ dose for each AOP stream for efficient removal of target MPs to the required log reduction, based on outcomes of initial scoping trials.

Chemicals were prepared to a required concentration and dosed directly into a 1 m³ storage tank, fitted with a submersible mixing pump, for holding the MF/RO permeate or blend. This feedwater was pumped to the UV unit with in-line H₂O₂ dosing upstream of a static mixer at flow rates of 1-3 m³ h⁻¹, providing residence times of 120-180 s. An experimental test comprised feed solution mixing for 20 minutes, to ensure a homogeneous solution, followed

by once-through AOP treatment for 20 minutes. Sampling of the outlet stream was timed to allow for the above residence time.

A daily 5 wt% citric acid CIP was performed on AOP1 to minimise sleeve fouling. The reactor was flushed through with the normal permeate stream following each experiment. Experiments were conducted separately for NDMA and MA to ensure no competition between the two sets of reactions; the EDCs, pesticides and herbicides were combined in the same bulk feedwater solution as applied in other studies (MWH, 2007). Duplicate samples for each MP compound were taken from the feed tank and triplicate samples collected post-AOP at 5, 10, and 15 minute intervals. Tests were repeated for any apparent anomalies.

Sampling and analysis was conducted for MPs along with standard sanitary determinants. All compounds were analysed by Thames Water Laboratories (Reading, UK) using standard methods (APHA, 2005). EDCs, atrazine and terbutryn were analysed by liquid chromatography with mass spectrophotometric detection (LS-MS-MS), ion chromatography (IC) was used to analyse NDMA, whilst the remaining herbicides and MA were analysed by gas chromatography (GC-MS).

Table 1: Mean and standard deviation values of feedwater quality parameters for each stream.

Compound	Unit	MF permeate	RO permeate	MF/RO Blend
Alkalinity as CaCO ₃	mg.L ⁻¹	212 ± 12.4	< 16	-
Conductivity	µS cm ⁻¹	1061 ± 15.3	20.8 ± 2.35	-
pH		7.3 ± 0.07	5.5 ± 0.05	7.14 ± 0.14
Hardness Total as CaCO ₃	mg.L ⁻¹	332.9 ± 16.7	< 29	-
Total Organic Carbon (TOC)	mg.L ⁻¹	7.7 ± 0.73	0.2 ± 0.17	4.85 ± 0.11
Turbidity	NTU	0.14 ± 0.21	0.08 ± 0.02	-
UV absorbance at 254 nm (UV ₂₅₄)	cm ⁻¹	0.18 ± 0.002	0.001 ± 0.002	0.11 ± 0.008
UV transmittance (UVT)	%	66 ± 0.82	98.8 ± 0.41	76.2 ± 1.44
Specific UV Absorbance (SUVA)	L.mg ⁻¹ .m.	2.34	0.5	2.26

Table 2: Operational conditions for the AOP spiking trials

Parameter	AOP1	AOP2
Feed water	MF filtrate	RO permeate
Lamp power set-point (%)	100%	60%
Power Input P / Optimal Range (kWh)	2.82/ 1.68 – 2.82	1.78/ 1.78 – 2.98
Lamp Life (h)	1380	1100
Peroxide dose/ Optimal Range (mg L ⁻¹)	16/ 6-20	3/ 1-3
Treatment capacity (m ³ h ⁻¹)	3	3
Reactor volume (m ³)	0.098	0.098
Theoretical contact time (s)	approx. 120	approx. 120

The optimisation trials were based on MA, the most recalcitrant of the micropollutants examined. Three equally-spaced H₂O₂ doses and power inputs were employed with each stream (MF permeate, RO permeate, and blend) and correlated with MA removal (Table 3). This approach allowed Box-Behnken design (Box and Behnken, 1960; Raffin *et al*, 2011) to be applied, reducing the number of experiments for a three-level, three-parameter study from 27 for a 3ⁿ factorial design to 15.

Table 3: Parameters and their levels, Box-Behnken analysis

Param. #	Parameters	Levels
X ₁	H ₂ O ₂ dose (mg L ⁻¹)	3, 9.5, 16
X ₂	UV-T (%)	65, 82, 98
X ₃	Power input (kWh)	1.68, 2.33, 2.98

Evaluated efficiency values were based on electrical energy per order (E_{EO}), as used by previous workers studying similar AOP systems (Bolton *et al*, 2001), along with specific energy demand (E_D) to benchmark against other advanced technologies such as RO. E_{EO} is defined by these authors as the electrical energy in kWh required to reduce the concentration of a contaminant by one order of magnitude in 1 m³.

$$E_{EO} = P / (Q \log (c_i / c_f)) \quad 1$$

where P is the electrical power (kW) of the UV system, Q is the flow rate (m³/h), and C_i and C_f the initial and final contaminant concentrations (mg L⁻¹). Specific energy demand (E_D), the electrical energy (kWh) consumed per unit volume of water treated, was also calculated so as to provide a further benchmark in cases where 90% (or 1 log) reduction was not achieved:

$$E_D = P / Q \quad 2$$

3 Results and discussion

3.1 MP removal

Measured concentrations (Table 4) revealed all the MPs studied to be removed by at least 97% when applying AOP to the RO permeate at an H₂O₂ dose of 3 mg L⁻¹ and an E_D of 0.62 kWh m⁻³. In contrast, application to the MF permeate was much less effective in removing herbicides and pesticides generally, and MA in particular. Even at very high H₂O₂ doses of 16 mg L⁻¹ with E_D levels of 0.93 kWh m⁻³, MA removal remained below 50%. Estrogenic substances (E1, E2 and EE2), on the other hand, were readily degraded (>99%) in both streams. These observations are consistent with those reported elsewhere (Ijpelaar *et al*, 2010; Rosenfeldt and Linden, 2004) for UV doses of 600-1000 mJ cm⁻² and H₂O₂ concentrations of 10-15 mg L⁻¹; >90% removal of these compounds was reported based on bench-scale UV/H₂O₂.

Differences in measured removal between the two permeate streams reflect those in UV transmittance (UVT) (Table 1), which is near total for the RO permeate compared with only 65% for the MF permeate. Higher doses of H₂O₂ in AOP1 were thus needed to compensate for the lower photon absorption efficiency (Tuhkanen, 2004). Moreover, competition for ·OH was greater in the MF stream due to significantly higher levels of scavengers (organic carbon, chloride and bicarbonate/carbonate ions), manifested as a higher E_{EO} value. pH would also be expected to influence oxidation efficiency since increasing pH converts more of the dissolved CO₂ to bicarbonate and so promotes scavenging (Liao and Gurol, 1995). However, reducing the MF permeate pH from ~7.2 to 5.5 was found to produce only a marginal increase (<10%) in metaldehyde removal. Other contributory factors, such as scaling/fouling of the lamp sleeves and other MF permeate water quality parameters (Stefan, 2004), would also be expected to reduce UV intensity and so AOP efficacy.

Table 4: Micro-pollutant removal results for Post MF and RO streams under optimum process conditions (power input and H₂O₂ dose).

Stream	Classifi- cation	Compound	Inlet Conc. ($\mu\text{g.L}^{-1}$)	% removal	Log reduction	UV Dose (mJ cm^{-2})	E_D (kWh m^{-3})	E_{EO} (kWh m^{-3})
AOP 1 (post- MF)	EDC	E1 Estrone	0.2	99	2.16	695	0.95	0.44
	EDC	E2 17- β Estradiol	0.2	99	2.11	695	0.95	0.45
	EDC	EE2 α Ethinyl Estradiol	0.2	99	2.32	695	0.95	0.41
	Herbicide	2,4-D	1	89	0.98	727	0.95	-
	Herbicide	Mecoprop	1	98	1.61	727	0.95	0.59
	Herbicide	2,4 5-T	1	85	0.83	727	0.95	-
	Pesticide	Atrazine	2	88	0.92	713	0.95	-
	Pesticide	Terbutryn	2	96	1.38	713	0.95	0.69
	Volatile	NDMA	0.2	98	1.62	678	0.95	0.59
	Pesticide	Metaldehyde	2	45	0.26	739	0.93	-
AOP 2 (post- RO)	EDC	E1 Estrone	0.2	99	3.25	2026	0.62	0.19
	EDC	E2 17- β Estradiol	0.2	99	3.21	2026	0.62	0.19
	EDC	EE2 α Ethinyl Estradiol	0.2	99	3.18	2026	0.62	0.19
	Herbicide	2,4-D	1	99	2.72	1825	0.62	0.23
	Herbicide	Mecoprop	1	99	2.60	1825	0.62	0.24
	Herbicide	2,4 5-T	1	99	2.70	1825	0.62	0.23
	Pesticide	Atrazine	2	98	1.62	1775	0.62	0.39
	Pesticide	Terbutryn	2	99	2.40	1775	0.62	0.26
	DBP	NDMA	0.2	99	2.39	1845	0.62	0.26
	Pesticide	Metaldehyde	0.2	98	1.70	2003	0.62	0.36

3.2 Metaldehyde removal

Tests conducted on MA specifically demonstrated increased removal with increasing UV and H₂O₂ dose (Fig. 2). However, metaldehyde was only significantly removed when the AOP was applied to the RO permeate, since the received UV dose was around five times greater than that for the MF permeate. Removal exceeded 95% at a peroxide dose of 2 mg L⁻¹ and an E_D of $\sim 0.7 \text{ kWh m}^{-3}$ (Fig. 3). Other studies have reported similar removal rates (Autin *et al.*, 2012), citing lower UV fluences of 600 mJ cm^{-2} for laboratory grade water, but at considerably higher H₂O₂ doses of 272 mg L⁻¹. For MF permeate, energy inputs above 0.75 kWh m^{-3} achieved no more than 40% removal (Fig. 3). Removal from MF permeate at a UV dose of around 460 mJ cm^{-2} ranged from 3 to 45% according to H₂O₂ concentration (Fig. 4).

Removal is, however, improved by H₂O₂ addition, particularly in poorer water quality. An increased H₂O₂ concentration may thus further increase degradation, provided the peroxide itself does not scavenge $\cdot\text{OH}$ at these elevated concentrations as suggested by other authors (Galbraith *et al.*, 1992). The relationship between UV dose and energy demand for each stream (Figure 5) indicates that higher UV doses are only attainable at the upper limits of UV transmittance at comparable energy demand. UV doses above 2000 mJ cm^{-2} with at $>2 \text{ mg L}^{-1}$ H₂O₂ appear sufficient to attain $>90\%$ removal of MA.




Figure 2. Effect of UV and H₂O₂ dose on the removal of metaldehyde from MF permeate (AOP1) and RO permeate (AOP2).




Figure 3. E_D data for metaldehyde degradation in MF (AOP1) and RO (AOP2) permeate as a function of H₂O₂ dose.




Figure 4. Metaldehyde removal from MF permeate as a function of H₂O₂ dose at UV dose 422-506 mJ cm⁻² and a power of 2.25kW.




Figure 5. Influence of UVT on the UV dose output as a function of energy input at various H₂O₂ concentrations (1-20 mg L⁻¹) in streams AOP 1 and 2.

3.3 Effect of residence time

Figure 6 shows the influence of retention time (RT) on MA removal from the MF permeate. Removal appears to increase from 40% to >75% on trebling RT from around two minutes, depending upon the power applied. UV intensity levels were increased 1.5-2 fold at extended

RTs, relative to the lamp power input (3.1 mW cm^{-2} at 1.67 kW ; 8.9 mW cm^{-2} at 2.82 kW). This probably results from improved UV_{254} transmittance (Stefan, 2004), which increased after AOP treatment in all experiments at higher UV doses in particular – presumably as a result of the rupturing of conjugated bonds in the NOM molecular structure (Toor and Mohseni, 2007).




Figure 6. Influence of residence time on the degradation of metaldehyde in MF permeate as a function of power input, $16 \text{ mg L}^{-1} \text{ H}_2\text{O}_2$.

3.4 Effect of UV transmittance (UVT)

The influence of UVT was quantified through blending of the MF and RO permeate streams in conjunction with power input and peroxide dose using a Box-Behnken design (BBD) based on the levels indicated in Table 3. Regression analysis revealed UVT_{254} and H_2O_2 dose (C) to be the only significantly influential parameters on metaldehyde removal (p-value < 0.05 for the linear coefficient in both cases), with power input having no significant impact (p-value 0.18) due to the limited range applied ($1.66 - 2.82 \text{ kW}$). The overall relationship between %metaldehyde passage (P) and peroxide concentration and UV transmittance (Fig. 7) from multiple linear regression analysis ($R^2 = 0.96$):

$$P = 671 - 16.2 C - 11.44 \text{ UVT} + 0.271 C^2 + 0.0497(\text{UVT})^2 + 0.1056 C \text{ UVT} \quad 3$$

The analysis indicates the extreme sensitivity of metaldehyde passage (1 - removal) to UVT, with passage at a dose of $8 \text{ mg L}^{-1} \text{ H}_2\text{O}_2$ ranging from 80% down to 8% on increasing the UVT from 65 to 90%. UV transmittance thus appears to be a significant parameter in determining the economic viability of AOP treatment for MA removal.




Figure 7. Effect of UV-T on metaldehyde passage (100-%removal) as a function of UV-T and H₂O₂ concentration, according to BBD analysis, 1.68-2.98kW power input (from Equation 3)

3.5 Operating expenditure (OPEX)

The operating cost of applying a UV/H₂O₂ AOP for MP removal is determined primarily by:

- the energy demand E_D of the UV device,
- the hydrogen peroxide demand, and
- the replacement frequency of critical, high-cost components.

The first two of these are defined by the outputs from Equation 3 (Figure 7), which permits computation of OPEX for water qualities pertaining to the MF and RO permeate based on the test conditions employed (Table 5). It is of interest to extend the OPEX calculation to include both other OPEX components and alternative treatment options for attaining a nominal target removal.

Table 5: AOP treatment conditions and associated OPEX relating to test conditions employed in the current study (MF and MF-RO pretreatment).

Parameter	MF-AOP	MF-RO-AOP
E_D , kWh.m ⁻³	2.17	0.50
UV dose, mJ cm ²	2600	2181
% MA removal	77	80
H ₂ O ₂ dose, mg L ⁻¹	16	1
OPEX* £ m ³		
Energy	0.241	0.072
Chemicals	0.033	0.002
Maintenance	0.099	0.099
TOTAL	0.373	0.173

*Electricity cost 0.11 £ kWh⁻¹ (Energy EU, 2012); 35% w/v H₂O₂ 0.59 £ L⁻¹ (Supplier); Pump rating 0.25 kW; H₂O₂ pump rating, 0.015 kW; Lamp life 9000h; citric acid CIP frequency 26 y⁻¹; citric acid CIP concentration 2.5 g L⁻¹

A recent study of municipal wastewater reuse based on the same plant as that employed in the current study provided projected costs of £0.069-0.084 m⁻³ for the MF process and £0.19-0.23 m⁻³ for the complete MF-RO process for flows of 25-100 MLD (Raffin, 2012). This compares with costs of £0.25-0.26 m⁻³ calculated for a similar MF-RO process (Garcia *et al*, 2013) for the same range of flow. The 62% figure for the mean proportion of the MF-RO OPEX attributed to the RO stage is very similar to the same parameter for the proportion of the energy demand (58%) averaged across six MF-RO municipal wastewater reuse plants worldwide (Raffin *et al*, 2013).

Since OPEX is primarily a function of the UVT, it is appropriate to consider the option of activated carbon (AC) for removing TOC which represents the main contributor to impaired UV transmittance. Recent trials, again based on the same plant (Hatt *et al*, 2013), have explored the options of employing powdered AC upstream of the MF, as well as downstream granular media beds (GAC). The outcomes suggest that either of these options can achieve 60-70% removal of UVT₂₅₄ from secondary wastewater, at a ~1500 bed volume capacity in the case of GAC. Based on a projected regeneration cost of £0.31-0.44 per kg (Supplier, 2013) and assuming a 5-10% loss of GAC per regeneration, this provides a GAC cost of £0.09 - 0.16 per m⁻³ of water treated.

The AOP E_D and peroxide demand values computed from Equation 3 associated with the treatment of water from MF, MF-AC, and MF-RO were determined from the water quality correlations based on >75% metaldehyde removal (Table 6). Combining the associated OPEX of these demand data (based on the assumptions listed in Table 5) allows the OPEX of the AOP stage to be determined for each of these streams. These can then be combined with the costs relating to the other unit operations (Table 7) to generate total OPEX values of the key candidate process treatment schemes (Figure 8), which exclude both labour and disposal costs but are otherwise based on similar conditions of feedwater quality (secondary municipal effluent).

Table 6: Calculated OPEX for AOP process within three treatment schemes for >75% metaldehyde removal.

Parameter	MF-AOP	MF-AC-AOP	MF-RO-AOP
E_D , kWh.m ⁻³	2.17	0.77	0.50
UV dose, mJ cm ²	2600	2196	2181
% removal	77	82	80
H ₂ O ₂ dose, mg L ⁻¹	16	5	1

Table 7: Comparable unit process OPEX, £ m⁻³

Process	Min	Max	Source
MF	0.069	0.084	Raffin (2012)
Total, MF-RO	0.19	0.228	Raffin (2012)
	0.25	0.26	Garcia <i>et al</i> (2013)
%RO of total	0.62	0.62	Raffin (2012)
AOP, post MF	0.373		James <i>et al</i> (this study)
AOP, post RO	0.176		James <i>et al</i> (this study)
AOP, post AC	0.199		James <i>et al</i> (this study)
GAC	0.09	0.16	Hatt <i>et al</i> (2013)

The OPEX data (Figure 8) indicate the MF-RO-AOP process to be slightly lower in cost (by ~20%) than either of the two other enhanced treatment process options (MF-AOP or MF-AC-AOP), whose OPEX values are comparable. However, the MF-RO-AOP option incurs an additional capital cost from the RO process stage, and relies on an appropriate route for disposal of the RO concentrate stream. All three options are considerably more costly, by between 70 and 190%, than the “standard” two-stage MF-RO process.




Figure 8. Projected OPEX values of four treatment schemes, based on 77-90% removal of metaldehyde from secondary municipal wastewater.

4 Conclusions

An extensive pilot-scale study of the efficacy of an advanced oxidation UV-H₂O₂ process for micropollutant (MP) removal has been conducted. Results indicate feedwater UV transmittance as being pivotal to the process economic viability, since this factor dramatically impacts on energy and/or oxidative chemical demand. Notwithstanding this, tests indicated all MPs other than metaldehyde and trihalomethanes to be removed by at least 85% by the AOP process when employed downstream of a microfilter (MF), with the estrogenic substances being more than 99% removed down to levels of ~1 ng L⁻¹. Under the conditions employed to achieve such removal, the calculated OPEX of the MF-AOP process is in the range of £0.32-0.40 m⁻³ – 50-70% higher than the MF-RO process but without the requirement for concentrate management.

Removal of the most recalcitrant MP metaldehyde (MA) by more than 75% demands improved transmittance of the wastewater using either a downstream reverse osmosis (RO) process or supplementary activated carbon (AC). Whilst the MF-RO-AOP process is around 20% lower in OPEX than the MF-AOP and MF-AC-AOP options and provides a higher water quality, a significant waste stream volume is generated in the form of the concentrate

stream. The OPEX of the enhanced, three-stage processes can be up to 2.2 times that of the standard MF-RO process.

Acknowledgments

The authors would like to thank Thames Water for financially supporting the study. Special acknowledgment goes to the whole Innovation Reuse team (Juliette Hatt and Marie Raffin in particular) for their technical support and assistance and the analytical laboratories for their contribution to the production of the data presented.

5 References

- Autin et al., 2013. The impact of background organic matter and alkalinity on the degradation of the pesticide metaldehyde by two advanced oxidation processes: UV/H₂O₂ and UV/TiO₂. *Water Research* 47 (6), 2041-2049.
- Autin, O., Hart, J., Jarvis, P., MacAdam, J., Parsons, S.A., Jefferson, B., 2012. Comparison of UV/H₂O₂ and UV/TiO₂ for the degradation of metaldehyde: Kinetics and the impact of background organics. *Water Research* 46 (17), 5655-5662.
- Baeza, C., Knappe, D. R. U., 2011. Transformation kinetics of biochemically active compounds in low-pressure UV photolysis and UV/H₂O₂ advanced oxidation processes. *Water Res.* 45, 4531-4543.
- Benotti, M.J., Stanford, B.D., Wert, E.C., Snyder, S.A., 2009. Evaluation of a photocatalytic reactor membrane pilot system for the removal of pharmaceuticals and endocrine disrupting compound from water. *Water Research* 43 (6), 1513-1522.
- Bolton, J. R., Bircher, K. G., Tumas, W. and Tolman. C. A., 2001. Figures-of-Merit for the Technical Development and Application of Advanced Oxidation Technologies for both Electric- and Solar-Driven Systems. *Pure & Applied Chemistry* 73 (4), 627-637.
- Box G.E.P., Behnken D.W., 1960. Some new three level designs for the study of quantitative variables. *Technometrics* 2 (4), p. 455-475.
- Desbrow, C. Routledge E.J. Brighty, G.C. Sumpter J.P. and Waldock, M., 1998. Identification of estrogenic chemicals in STW effluent. 1. Chemical fractionation and in vitro biological screening. *Environmental Science & Technology* 32 (11), 1549-1558.
- EC, 2000. European Community Directive 2000/60/EC of the European Parliament and of the Council on establishing a framework for the Community action in the field of water policy. *Official Journal of European Community* 22/12/00, L327, 1-73.
- Energy EU., 2012. <http://www.energy.eu/> Website accessed 19th Sept. 2012.
- Galbraith, M., Shu, M.-M., Davies, S.H., Masten, S.J., 1992. Use of ozone, ozone, peroxide, and ozone/ UV for the generation of OH radicals to oxidize chlorinated organics. Presented at the 24th Mid-Atlantic Industrial Waste Conference, Morgantown, WV, 411-430.
- Garcia, N., Moreno, J., Cartmell, E., Rodriguez-Roda, I., and Judd, S., 2013. The cost and performance of an MF-RO/NF plant for trace metals removal, *Desalination* 309 181-186
- Hatt, J.W., Germain, E., Judd, S.J., 2013. Granular activated carbon for removal of organic matter and turbidity from secondary wastewater. *Water Science & Technology* 67 (4), 846-853.

Hernandez, R., Zappi, M., Colucci, J., Jones, R., 2002. Comparing the performance of various advanced oxidation processes for treatment of acetone contaminated water. *Journal of Hazardous Materials* 92, 33-50.

Holm, P., 2011. Linking water quality to human health and environment: The fate of micropollutants. Series: Working Paper Series / Institute of Water Policy, National University of Singapore; IWP/WP, No. 3

Hotchkiss, A.K., Rider, C.V., Blystone, C.R., Wilson, V.S., Hartig, P.C., Ankley, G.T., Foster, P.M., Gray, C.L., Earl Gray, L., 2008. Fifteen years after “wingspread” – environmental endocrine disrupters and human and wildlife health: where we are today and where we need to go. *Toxicological Sciences*. 105 (2), 235-259.

Ijpelaar, G.F., Harmsen, D., Sharpless, C.M., Linden, K.G., Kruithof, J.C., 2006. Fluence Monitoring in UV Disinfection Systems: Development of a Fluence Meter, AwwaRF report 91110.

Ijpelaar, G.F., Harmsen, D.J.H., Beerendonk, E.F., van Leerdam, R.C., Metz, D.H., Knol, A.H., Fulmer, A., Krijnen, S., 2010. Comparison of low pressure and medium pressure UV lamps for UV/H₂O₂ treatment for natural waters containing micro pollutants. *Ozone: Science Engineering* 32 (5), 329-337.

Katsoyiannis, I.A., Canonica, S., Von Gunten, U., 2011. Efficiency and energy requirements for the transformation of organic micropollutants by ozone, O₃/H₂O₂ and UV/ H₂O₂. *Water Research* 45, 3811-3822.

Liao, C.H., Gurol, M.D., 1995. Chemical oxidation by photolytic decomposition of hydrogen peroxide. *Environmental Science & Technology* 29 (12), 3007-3014.

Linden, K.G., Rosenfeldt, E.J., Kullman, S.W., 2007. UV/H₂O₂ degradation of endocrine-disrupting chemicals in water evaluated via toxicity assays. *Water Science & Technology* 55 (12) 313-319.

Matilainen, A., Sillanpää, M., 2010. Removal of natural organic matter from drinking water by advanced oxidation processes. *Chemosphere* 80, 351-365.

MWH Global, 2007. City of San Diego Advanced Water Treatment Research Studies. Final Report, City of San Diego.

Poussade, Y., Roux, A., Walker, T., Zavlanos, V., 2009. Advanced oxidation for indirect potable reuse – A practical application in Australia. *Water Science & Technology* 60 (9), 2419-2424.

Raffin, 2012. Optimisation of membrane technology for water reuse, PhD thesis, Cranfield University.

Raffin, M., Germain, E., Judd S., 2011. Optimising operation of an integrated membrane system (IMS) - A Box-Behnken approach. *Desalination* 273 (1) 136-141.

Raffin, M., Shiffar, A., Judd, S.J., 2013. A review of membrane-based water reuse plants: trends and implications. *Environmental Technology*, in press.

Rosario-Ortiz, F.I., Wert, E.C., Snyder, S.A., 2010. Evaluation of UV/H₂O₂ treatment for the oxidation of pharmaceuticals in wastewater. *Water Research* 44, 1440-1448.

Rosenfeldt, E.J., Linden, K.G., 2004. Degradation of endocrine disrupting chemicals bisphenol A, ethinyl estradiol, and estradiol during UV photolysis and advanced oxidation processes. *Environmental Science & Technology* 38 (20), 5476-5483.

Royce, A., Khoo., K., Festger, A., Muller, J., Stefan, M., Mao, T., Cairns, B., 2010. UV disinfection fundamentals. In: The guidebook to membrane technology for wastewater reclamation, edited by Wilf, M. Ch. 18. 1st Ed., Balaban Desalination Publications, Hopkinton, USA.

Sanches, S., Crespo, M.T. B., Pereria, V.J., 2010. Drinking water treatment of priority pesticides using low pressure UV photolysis and advanced oxidation processes. Water Res. 44, 1809-1818.

Stefan, M., 2004. UV Photolysis: background. In: Advanced Oxidation Processes for Water and Wastewater Treatment, edited by S. Parsons. Ch 2. IWA, London.

Snyder, S.A., Wert, E.C., Lei, H.D., Westerhoff, P., Yoon, Y., 2007. Removal of EDCs and Pharmaceuticals in Drinking and Reuse Treatment Processes. Awwa Research Foundation, Denver CO.T

WSR, 2000. The Water Supply (Water Quality) Regulations (WSR) 2000. The Stationary Office Limited, London, ISBN 0110973844.

Water UK, 2009. Water Company Proposed PR09 Catchment Management Schemes. November 2009, 15-16.

Micropollutant removal by advanced oxidation of microfiltered secondary effluent for water reuse

James, Christopher P.

2014-04-30T00:00:00Z

NOTICE: this is the author's version of a work that was accepted for publication in Separation and Purification Technology. Changes resulting from the publishing process, such as peer review, editing, corrections, structural formatting, and other quality control mechanisms may not be reflected in this document. Changes may have been made to this work since it was submitted for publication. A definitive version was subsequently published in Separation and Purification Technology, Volume 127, 30 April 2014, Pages 77–83. DOI10.1016/j.seppur.2014.02.016

Christopher P. James, Eve Germain and Simon Judd. Micropollutant removal by advanced oxidation of microfiltered secondary effluent for water reuse. Separation and Purification Technology, Volume 127, 30 April 2014, Pages 77–83.

<http://dx.doi.org/10.1016/j.seppur.2014.02.016>

Downloaded from CERES Research Repository, Cranfield University