

Exergetic and Sustainability Analysis of an Intercooled Gas Turbine Cogeneration Plant with Reverse Osmosis Desalination System

Abdulrahman Almutairi*,¹, Pericles Pilidis², Nawaf Al-Mutawa³, Mohammed Al-Weshahi⁴

¹ Researcher, Cranfield University, School of Aerospace, Transport and Manufacturing, Power and Propulsion Department, Cranfield, Bedfordshire MK43 0AL, UK (corresponding author). Email: a.s.almutairi@cranfield.ac.uk.

² Professor, Cranfield University, School of Aerospace, Transport and Manufacturing, Power and Propulsion Department, Cranfield, Bedfordshire MK43 0AL, UK

³ Assistant Professor, Kuwait University, College of Engineering and Petroleum, Alkhalidiya, P.O.Box 5969 Safat 13060, Kuwait

⁴ Assistant Professor, Shinas College of Technology, Engineering Department, Shinas, P.O.Box 77, Oman

Abstract

In this paper, an advanced cogeneration plant based on a 100 MW aero-derivative intercooled gas turbine (ICGT) engine and large two-pass reverse osmosis (RO) desalination system is analyzed thermodynamically. The proposed model has been developed using the IPSEpro software package and validated with manufacturers' published data. Saline water is simulated using the latest physical properties available in the literature and treated as a real mixture. Combined energetic and exergetic performance criteria for the design of a cogeneration plant is presented as being, today, the most efficient method for accurate assessment of performance which also permits quantification of system deficiencies. The performance of the proposed plant was investigated using different loads, ambient temperatures, pressure ratios and feed water temperatures. The results show an intercooler system improves cogeneration plant performance despite having a negative impact on the combustion chamber performance because of its reduction of compressed air temperature.

The ICGT engine is considered to be the best available choice to integrate with an RO unit because of its high-pressure ratio and low power consumption in the compressors. From an operational perspective full load, low ambient and high feed water temperatures are highly recommended. The exergetic efficiency of the ICGT engine, RO system and cogeneration plant are shown to be 44.3 %, 32.83 % and 47.6% respectively. From a sustainability perspective, the exergetic–environmental efficiency is slightly affected by ambient temperature while highly affected by load variation. Based upon the obtained results, numerous possibilities are presented to improve the performance of cogeneration plant.

1- Introduction

The rate of depletion of non-renewable energy and water has increased enormously over the last century to meet the demands of increased economic activities, rapid increases in population and changes in lifestyle which has had serious adverse effects on environmental sustainability. Cogeneration systems to supply power and clean water from a single fuel source have a relatively high performance, low production cost and environmental impact compared to separate power and desalination plants. The most common technology used for electrical generation today is the GT whereas in water technology reverse osmosis (RO) is predominant. In the current study, these two systems are integrated as shown in Figures 1 and 2.

Exergy represents the maximum obtainable work from a system under reversible conditions. Exergy analysis is a decisive tool to assess the efficiency of energy systems especially when the product has a different energy form and quality. It reveals the sources and magnitudes of irreversibilities within a system. Exergy analysis is governed by the first and second laws of thermodynamic, and it is not conserved and adjusted by waste exergy.

In last two decades, numerous exergy studies have been performed on RO plants in standalone mode, but only a few have focused on RO plants in cogeneration systems. Cerci (2002) performed an exergy analysis study for a 7250 m³/d RO plant located in California and alternative designs were explored in order to improve plant performance. The exergetic efficiency of the plant was low, equal to 4.3%, and the proposed alternative design had an exergetic efficiency of 4.9%, only slightly higher than the original plant. In that study, the thermo-physical properties of seawater were treated as an ideal mixture.

Wanga and Tang (2013) produced an exergetic analysis of a two-stage RO desalination plant, which resulted in two main findings. First, increasing the number of stages raises the input pressure, resulting in higher exergy and total exergy destruction. Second, exergetic efficiency can be improved by heating the feed water and increasing product flow usage. Ternero, et al.

(2005) conducted an exergetic study of a 21,000 m³/d RO plant located in Spain. The main observation was that about 80% of exergy destruction occurred in the core unit, which consisted of high pressure pumps, membrane modules and valve regulation. Aljundi (2009) introduced second-law analysis using actual plant data from a 1,600 m³/d RO plant located in Jordan. The results of this study show the highest exergy destruction occurred in the membrane modules and throttling valve, confirming the findings of Cerci (2002). Al-Zahrani et al. (2012) conducted a thermodynamic analysis of a RO desalination unit with energy recovery. Three configurations were introduced into the desalination unit; (i) a throttling valve in the rejection section, (ii) an hydraulic turbine and (iii) a pressure exchanger system (PX) used as an energy recovery device (ERD). The results showed that plant performance was significantly affected by applied pressure, feed water salinity and temperature. El-Emam and Dincer (2014) investigated the performance of a 7586 m³/d RO desalination plant with an integrated energy recovery Pelton turbine, at different seawater salinity values. The exergy analysis showed that the energy recovery device reduced exergy destruction by 35.5%, compared to expansion valves. The recovery ratio of ERD was inversely proportional to product unit cost.

Sharqawy et al. (2011b) carried out exergetic analysis on a RO desalination plant using the latest available thermodynamic properties of seawater instead of treating it as an ideal mixture consisting purely of H₂O and NaCl. The results showed a significant difference between the results obtained using an ideal mixture and real properties, especially with regard to exergetic efficiency and energy consumption values.

Mistry et al. (2011) carried out exergetic analysis for different desalination technologies using a new definition for useful exergy output. In their study, the exergetic efficiencies of RO, ME-TVC, MED, and MSF were found to be 31.9 %, 8.5 %, 5.9 % and 2.9% respectively. Kempton et al. (2010) investigated the thermodynamic efficiencies and greenhouse-gas emissions for three alternative desalination technologies. The result show that the highest exergetic efficiency

occur with RO at 30.1% followed by 14.3% MED and 7.7% MSF. Dashtpour and Al-zubaidy (2012) applied energy analysis to a RO plant using new a scheme to reduce electrical power consumption per unit volume of fresh water. Farooque et al. (2008) conducted energetic analyses of RO plant utilizing energy recovery devices. According to the study, the power consumption of the high-pressure pump was highly dependent on ERD efficiency and seasonal operating conditions.

In recent years, several studies have proposed environmental indicators based on an exergy analysis. Midilli and Dincer (2009) developed new exergetic–environmental indicators for a polymer electrolyte membrane fuel cell in order to measure environmental impact and sustainability. Some of these indicators were applied by Aydin (2013) to an aeroderivative GT. In this context, the present authors (Almutairi et al, 2015a), have developed a new indicator, termed exergetic–environmental efficiency, which relates exergetic efficiency and power output with exhaust gas production. The exergetic-environmental efficiency is considered to be a good indicator for measuring environmental impact resulting from energy system emissions. The amount of carbon dioxide [CO₂] was selected as a parameter to represent exhaust gases, as it is highly affected by energy system efficiency. The exergetic–environmental efficiency can be expressed as the ratio between the actual values and the stoichiometric value of CO₂.

This article describes a study in which energy and exergy analyses were performed on a cogeneration plant based on an advanced aero-derivative ICGT integrated with a two-pass large RO unit. The current study aims to contribute to the literature by:

- ❖ Developing a comprehensive model for a cogeneration plant based on exergy analysis using real data sets.
- ❖ Evaluating a two-pass RO desalination plant of an industrial scale using the most recent thermo-physical properties of seawater, treated as a real mixture.
- ❖ Examining the effects of intercooling on exergy destruction of all components.

2- Cogeneration plant: system description

In this study, a cogeneration system based on an ICGT engine and RO desalination plant was investigated, see Figure 1. The ICGT engine was inspired by the LMS 100 GE, a state-of-the-art aero-derivative GT. The desalination plant was inspired by the Al Shuwaikh RO desalination plant, see Figure 2, which is located in the state of Kuwait. The validation of the two models using manufacturer's data is shown in Appendix-A.




Figure 1. Schematic diagram for the intercooled gas turbine engine.

2.1 Intercooled Gas Turbine Engine

The ICGT engine is distinguished by intercooling modification of the GT system, and in today's market it has the highest claimed power output and efficiency (for simple cycles). Intercooling is an important technique that increases net GT power output by reducing compressor power consumption. With the intercooling system, the power consumption of the HPC is reduced, increasing overall efficiency. The ICGT system consists of three shafts (F', G' and H'), as shown in Figure-1.

Shuwaikh R.O Desalination Plant




Figure 2. Schematic diagram for the Shuwaikh RO Desalination Plant (MEW, 2008).

The first shaft is connected to the low-pressure components; the second, to the high-pressure components; and the third, to the power turbine. The cold section consists of the low-pressure compressor (LPC), high-pressure compressor (HPC) and the intercooler situated between them. The compressed air is delivered from the LPC to the intercooler to reduce the inlet temperature of the HPC by extracting heat. The work required to drive the HPC is reduced and leads to an increase in engine output power.

There is one negative impact of the intercooling process, the lower temperature of the air being delivered to the combustor, which increases the fuel consumption in the engine. The overall pressure ratio in the LPC and HPC compressors is 42. To reduce pressure losses two scroll casings have been introduced, one at the exit of the LPC before the intercooler, and the second at the inlet of the HPC. The high-pressure compressed air moves forward to the annular combustor and, mixed with fuel, results in hot, gaseous, products of combustion which are directed into the turbine section and expand through the high-pressure turbine (HPT), intermediate-pressure turbine (IPT), and low-pressure turbine (LPT) or power turbine (PT). The HPT and IPT are driven by the HPC and LPC whereas the LPT produces the power output. The thermal efficiency and capacity of the ICGT engine are about 45% and 100 MW under International Standards Organization [ISO] conditions. The stream of exhaust gases exits from the stack at atmospheric pressure and temperature of about 685 K. ICGT performance data is presented in Table 1.

2.2 RO Desalination Plant

The RO desalination plant is driven by the ICGT. A small portion of the power generated by the ICGT is directly consumed by the RO plant, and the majority is exported to the electrical network. The intake of the Shuwaikh RO desalination plant is on the coast of the Arabian Gulf, which has a high salinity, reaching 45,000 ppm. The design capacity of the inlet is about 425,000 m³/d. The seawater supply pumps (SSP) draw seawater from the intake area and

deliver it into the dissolved air flotation (DAF) system. The feed water is treated physically and chemically in the DAF system to remove or separate the colloidal solids, oils and greases. The feed water moves forward through strainers and a static mixer via filter feed pumps (FFPs). Next, the feed water is directed to the ultrafiltration (UF) system where large macromolecules, colloids, bacteria and proteins are removed. The UF system has a membrane with large pore sizes compared to the membrane modules in the RO unit.

Table 1. Performance data of proposed cogeneration system.

	Description	Value	Unit
ICGT	GT Power output	98.70	MW
	Thermal efficiency	45	%
	Heat rate	7921.00	kJ/kWh
	Compressor Pressure ratio	42	----
	Exhaust Mass flow	222	Kg/s
	Exhaust Temperature	412	°C
RO Desalination Plant	Number of SWRO stages	10	----
	Number of BWRO nit stages	4	----
	Seawater feed temperature	15	°C
	Seawater salinity	45000	ppm
	Design mass flow rate	4921.1	Kg/s
	Permeate mass flow rate	1611.1	Kg/s
	Rejected mass flow rate	3342.8	Kg/s
	SWRO permeate mass flow rate	1750	Kg/s
	SWRO bypass permeate mass flow rate	361.1	Kg/s
	SWRO permeate mass flow rate	1250	Kg/s
	BWRO rejected mass flow rate	138.8	Kg/s
	Permeate salinity	less than 200	ppm
	Brine salinity	66279	ppm
	SSP discharge pressure	2.5	bar
	FFP discharge pressure	5.5	bar
	UF Backwash discharge pressure	4.5	bar
	ERD booster pump discharge pressure	66.7	bar
	SWRO HPP discharge pressure	66.7	bar
	BWRO HPP discharge pressure	13.7	bar
	SWRO recovery ratio	42	%
BWRO recovery ratio	90	%	

The treated feed water is mixed with brackish water from the second pass RO unit, in the static mixer, then moves to the high-pressure pump (HPP). After that the high pressure feed water is mixed with the discharge stream from the ERD booster pumps, after which it enters the first RO unit (which consists of 10 stages). The exit stream splits into two main streams with different salinities. The permeate exiting from the first unit is also divided into two streams, the first is used as a feed to the second RO unit (4 stages) while the second blends with the permeate stream exiting from the second RO unit and is moved to the product tank by the product water pump. The product stream has a capacity of 136,000 m³/d with a salinity less than 200 ppm. The brine water of the first RO units returns to the main stream after passing through the pressure exchanger and booster pumps. The exiting brine water from the second RO unit is also returned to the main stream and mixes with the feed water, but after the UF system has reduced its salinity. The pressure exchanger system reduces the energy consumed in the first RO unit by about 50%, especially at high feed salinity. The RO desalination plant contains a sophisticated pretreatment process prior to the thermal processes and which requires more than twenty different chemicals to protect the RO unit during its operation (Darwish, 2014) . The RO desalination plant performance data is also shown in Table 1.

3- Methodology

Comprehensive energetic and exergetic studies were performed for a simulated cogeneration system inspired by real power generation and desalination units. The proposed system performance was investigated at different loads, ambient temperatures, feed water temperatures and pressure ratios. The following assumptions were made about the cogeneration system :-

- The proposed model operated at steady state conditions.
- Intake air and combustion products in the ICGT could be treated as ideal gas mixtures.
- The effects of kinetic and potential exergies could be omitted.
- Combustion was complete, and N₂ was inert.

- The supplied fuel was natural gas.
- The pump efficiency was 75%, as published in (Kahraman and Cengel , 2005).
- The intake conditions were 288 K and 45000 ppm, and these were taken as the reference state.

3.1 Seawater thermo-physical properties

The modelling developments reported here and previously (Almutairi et al, 2016) , have taken into account the thermophysical properties seawater, its composition and, particularly, chemical exergy. This is considered important because seawater contains a strong electrolyte which makes the ideal mixture concept inapplicable. Treating seawater as an ideal mixture produces unrealistic negative exergetic values in the different streams which offends against the second law of thermodynamics where the exergy must be equal to, or greater than zero. Nevertheless, for the sake of simplicity, some researchers such as (Hou et al. , 2007) have assumed seawater to be pure water. Ignoring the low salt percentage in seawater will have adverse effects on desalination plant design (Sharqawy et al. , 2010). However, the present study uses the latest published data on thermo-physical properties as given by Sharqawy et al. (2011a) . The calculations and results for density, specific enthalpy, specific entropy and chemical potential are given Appendix-B.

3.2 Energy analysis

Exchange of energy for any system results in work and heat transfer through a specified domain. Conservation of energy maintains the sum of all energies in that region is constant because internal losses are not considered. For a generally steady state condition the energy equation state can be expressed as:

$$\dot{Q} - \dot{W} = \Delta H + \Delta Ke + \Delta Pe \quad (1)$$

The heat transfer and work done are represented on the L.H.S. of Equation (1) while the change in enthalpy, kinetic and potential energies are respectively represented on the R.H.S. Energy

analysis is considered a useful tool to calculate thermal efficiency, power output, heat release and enthalpies. Detailed calculations of air to fuel ratio in the combustion chamber is shown in Appendix-C.

3.3 Exergy analysis

Exergy analysis has become an important method for evaluating energy systems and is widely applied to determine type, location and magnitude of thermodynamics inefficiencies. Thus, it can play a decisive role in improving the performance of existing plants or design of new projects. Exergy analysis combines the principles of mass and energy conservation with the second law of thermodynamics. Unlike energy, exergy is not conserved and is highly effected by the quality of the energy. In the absence of nuclear reaction, surface tension, magnetism and electricity the total exergy will consist of four components; physical, chemical, kinetic and potential (Hepbasli , 2008). The exergy balance of a system is given by:

$$\dot{E}_x = \dot{E}_{ph} + \dot{E}_{ke} + \dot{E}_{pe} + \dot{E}_{ch} \quad (2)$$

Kinetic, \dot{E}_{ke} , and potential, \dot{E}_{pe} , exergies are commonly associated with the movement and elevation of particles, respectively, but are omitted from the present study due to their negligibly small contributions. Physical exergy consists of thermal and mechanical exergy and is defined as the maximum obtainable useful work from a unit mass of substance proceeding from a specified state (T_s, p_s) to the environmental state (T_o, p_o) (Querol et al., 2012). The physical exergy is given by the expression:

$$\dot{E}_{ph} = \dot{m}[(h_s - h_o) - T_o(s_s - s_o)] \quad (3)$$

Where the subscripts (s) refers to specified state and (o) for the corresponding environmental state. Once the specified temperature and reference temperature are equal, then for gases streams equation (3) becomes:

$$\dot{E}_{ph} = \dot{m}RT_o \ln \frac{P_s}{P_o} \quad (4)$$

When the system reaches full equilibrium (both physical and chemical) with the local environment, it is said to be in “dead state”, and it has zero exergy. Chemical exergy is defined as the maximum energy that can be extracted from the stream as the flow reaches its dead state due to, for example, differences in molecular structure and concentration. The chemical exergy of the fuel, gas mixtures and saline water can be calculated using the following equations respectively:

$$\dot{E}_{ch} = \dot{n} \overline{LHV} \quad (5)$$

$$\dot{E}_{ch} = \dot{n} [y_k e_k^{-ch} + \bar{R} T_o \sum y_k \ln(y_k)] \quad (6)$$

$$\dot{E}_{ch} = \dot{m} \sum w_k (\mu_k^s - \mu_k^*) \quad (7)$$

Where the superscripts (*) refer to the dead state. The \dot{n} , e_k^{-ch} and μ_k represents number of mole rate, specific molar chemical exergy and chemical potential for component k in the mixture. The specific molar chemical exergies are presented in the table for different substance as published in Bejan et al. (1996), Ahrendts (1980) , Almutairi et al. (2015b) and Khaliq (2015).

The exergetic efficiency assesses the actual performance of an energy system from a thermodynamic view. The exergetic efficiency is defined as the ratio of product to fuel exergy for a system or component, i.e.:

$$\eta_{ex} = \frac{\dot{E}_p}{\dot{E}_f} = 1 - \frac{\dot{E}_d + \dot{E}_l}{\dot{E}_f} \quad (8)$$

Where \dot{E}_p , \dot{E}_f , \dot{E}_d and \dot{E}_l represent rates of production of exergy, fuel exergy, exergy destruction and exergy loss respectively. Exergy destruction is associated with irreversibilities within a component whereas exergy loss relates to energy emitted to the environment during the process or at the end. Inlet exergy to the component is always higher than outlet exergy by the value of the waste exergy as shown in the following equation.

$$\dot{E}_e = \dot{E}_i - \dot{E}_d - \dot{E}_l \quad (9)$$

The exergy loss \dot{E}_l for a certain component is equal to zero at the adiabatic condition. In the desalination process, the minimum work of separation represents exergy product whereas the fuel exergy is equal to electrical energy supplied to the system. Hence, the exergetic efficiency of RO system can be written as:

$$\eta_{ex} = \frac{\dot{W}_{min}}{\dot{E}_f} \quad (10)$$

3.4 Sustainability Indicator

Exergy plays an important role in sustainable development, because it offers a common basis of assessment for diverse energy resources, and addresses concerns about the quality and quantity of energy. Environmental impact decreases and sustainability increases as the energy system's exergetic efficiency increases. Awareness of this important relationship between exergy and the environment may help reveal patterns in adverse changes to the environment, and assist researchers to better assess likely environmental damage. Rosen and Dincer (2012) reported three relationships between exergy and the environment, as illustrated in Figure 3.




Figure 3: Exergy analysis with three forms of environmental damage.

Exergetic-environmental efficiency is considered to be a good indicator to assess likely environmental impact resulting from emissions from energy systems. The amount of CO₂ in

the exit gases was selected as the variable to represent emissions because it is highly affected by engine efficiency. Thus, exergetic–environmental efficiency is expressed as the ratio between actual values per MWh to the stoichiometric values of CO₂, and can be written as:

$$\xi_{CO_2} = \frac{\varphi_{ac}}{\varphi_{st}} \quad (11)$$

The stoichiometric value, φ_{st} , of CO₂ can be calculated using molar analysis, whereas the actual value is obtained from the HEPHAESTUS generic combustor model. A cogeneration plant producing power and water as reported in the literature (Al-Weshahi et al. ,2013 ; Al-Sulaiman et al. , 2011 ; and Almutairi et al., 2016) generally considers the useful energy supplied to the desalination plant as addition energy equivalent to the amount of water produced. Thus the CO₂ produced by the cogeneration of electricity and water has been expressed as:

$$\varphi_{cogen} = \frac{\dot{m}_{CO_2}}{\dot{W} + \dot{Q}_{in}} \quad (12)$$

This approach does not reflect the real status of CO₂ emission because it is based on the assumption of utilising an amount of energy with 100% efficiency, which is far from reality. The conflict comes from the nature of the product which is not energy and the low exergetic efficiency of desalination plants. However, using an energy input in the CO₂ generation equation for a cogeneration plant can be justified as equivalent to having a stand-alone desalination plant using an industrial boiler, in spite of the different configurations between them. That shows substantial reduction in CO₂ intensity per MWh and augments the cogeneration principle, but does not permit an accurate evaluation of CO₂ emissions.

In this study, a new approach is proposed that is compatible with the desalination process as a low-grade heat recovery technology. The CO₂ intensity equation uses minimum work of separation (\dot{W}_{min}) instead of energy input and can be written as:

$$\varphi_{cogen} = \frac{\dot{m}_{CO_2}}{\dot{W} + \dot{W}_{min}} \quad (13)$$

4- Results and discussion

This section presents the results of energetic and exergetic analyses of a cogeneration system (ICGT-RO) under different conditions. The effect of load variations, climatic conditions, pressure ratios, the number of stages and feed water temperatures have been investigated. The reference and dead state for water streams subject to the intake conditions $T = 288 \text{ K}$, $P = 1.01 \text{ bar}$, and $w_s = 45,000 \text{ ppm}$. The streams of the topping cycle have the same reference conditions. The topping cycle and RO unit streams are denoted by letters and number respectively as illustrated in Figures 1 and 2. The exergetic data of the proposed cogeneration system at various locations are shown in Tables 2 and 3. The proposed model of the power and desalination plant were validated with manufacturer's published data and showed high compatibility. The validation was considered a necessary step prior to examining the model or commencing the analysis to maximise the reliability of the results.

Table 2. The exergetic data at various locations in RO plant.

Point	Location	Fluid	Mass Flow (kg/s)	Pressure (bar)	Salinity (ppm)	Enthalpy (kJ/kg)	Entropy (kJ/kg. K)	Exergy Rate (MW)
0	Intake – SSP Inlet pump	Saline water	4934	1.01	45000	59	0.21	0.00
1	SSP Outlet	Saline water	4934	2.51	45000	59	0.21	0.72
2	DAF Outlet/ FFP Inlet	Saline water	4603	2.26	45000	59	0.21	0.56
2A	FFP Outlet/ Strainers Inlet	Saline water	4603	5.63	45000	60	0.21	2.05
3	UF Inlet	Saline water	4573	5.51	45000	60	0.21	1.99
4	UF Outlet	Saline water	3998	4.51	45000	59	0.21	1.35
5	Backwash Tank Inlet	Saline water	575	4.01	45000	59	0.21	0.17
6	SWRO HPP Inlet	Saline water	1773	4.51	43700	60	0.21	0.60
6A	ERD PX Inlet	Saline water	2300	4.50	43700	60	0.21	0.78
7	SWRO HPP Outlet	Saline water	1773	66.72	43700	68	0.22	11.27
7A	ERD BP Outlet	Saline water	2314	68.00	48300	65	0.21	14.98
8	First RO Unit Inlet	Saline water	4086	66.72	46300	67	0.21	25.94
9	First RO Unit Outlet	Fresh water	1719	1.50	700	65	0.23	5.91
10	First RO Unit Outlet	Brine water	2367	65.22	79400	63	0.19	16.14
10A	ERD Outlet/ BP Inlet	Saline water	2314	63.10	48300	65	0.21	13.88
11	ERD Outlet/To Outfall	Brine water	2354	1.30	75100	57	0.19	1.49
12	Bypass Line	Fresh water	348	1.50	700	65	0.23	1.19
13	BWRO HPP Inlet	Fresh water	1371	1.49	700	65	0.23	4.71
13A	BWRO HPP Outlet	Fresh water	1371	13.71	700	67	0.23	6.39
14	Second RO Unit Outlet	Fresh water	1232	1.50	100	65	0.23	4.38

Point	Location	Fluid	Mass Flow (kg/s)	Pressure (bar)	Salinity (ppm)	Enthalpy (kJ/kg)	Entropy (kJ/kg. K)	Exergy Rate (MW)
15	Second RO Unit Outlet	Brackish	139	11.11	6100	66	0.23	0.48
16	Permeate Tank Outlet	Fresh water	1580	1.50	200	65	0.23	5.59
16A	PWP Outlet	Fresh water	1580	4.50	200	66	0.23	6.06
17	Internal Consumption	Fresh water	32	4.50	200	66	0.23	0.12
18	To Product Tank	Fresh water	1547	1.01	200	64	0.23	5.39
19	UFP Outlet/UF Inlet	Saline water	575	4.51	45000	59	0.21	0.19
20	DAF Outlet/WWP Inlet	Saline water	91	1.00	45000	59	0.21	0.00
21	TO Neutralization pit	Saline water	91	1.00	45000	59	0.21	0.00
22	TO Waste Water	Saline water	91	1.50	45000	59	0.21	0.00
23	TO CWE Tank	Fresh water	0	4.50	200	66	0.23	0.00
24	Strainer Inlet	Saline water	3023	1.10	68400	58	0.19	1.21
25	TO Outfall Channel	Brine water	3023	1.10	68400	58	0.19	1.21
26	UF Outlet/To Outfall	Saline water	488	2.51	45000	59	0.21	0.07

Table 3. The exergetic data at various locations in ICGT engine at ISO condition

Point	Location	Fluid	Mass Flow (kg/s)	Temp. (K)	Pressure (bar)	Enthalpy (kJ/kg)	Entropy (kJ/kg. K)	Exergy Rate (MW)
A	LPC Inlet	Air	217.1	288	1.01	15.01	6.85	0.29
B	LPC Outlet/ Cooler Inlet	Air	217.1	420.84	3.44	149.85	6.88	27.53
C	Cooler Outlet/ HPC Inlet	Air	217.1	325.36	3.28	52.80	6.63	21.95
D	HPC Outlet/CC Inlet	Air	217.1	701.55	42	444.73	6.69	103.09
E	CC Inlet	Fuel	4.93	288	45	22.27	---	222.89
F	CC Outlet/HPT Inlet	Exhaust Gases	222.03	1490	39.82	1428.67	7.81	265.63
G	HPT Outlet/ IPT Inlet	Exhaust Gases	222.03	1182.4	12.656	1037.66	7.85	173.17
H	IPT Outlet/ LPT Inlet	Exhaust Gases	222.03	1073.5	8.02	903.14	7.87	145.39
I	LPT Outlet/ Stack	Exhaust Gases	222.03	685	1.013	444.85	7.95	38.72




Figure 4. Exergy flow as a percentage of input fuel exergy.

Figure 4 uses a Grossman diagram to illustrate exergy flow across a cogeneration system at ISO conditions. Even though the ICGT contributes more useful exergy compared to the RO desalination unit, it has more exergy destruction. The fuel exergy of the RO unit is about 9.9

%, which is low, and shows how power production dominates plant performance. The system has a high exergy loss value that can be reduced by integrating the current system with a low-grade heat recovery system to utilize heat contained in the gaseous products of combustion before they are emitted to the environment. The high value of exergy destruction in the combustion chamber of the proposed system open further possibilities to enhancing performance. The technique of improvement depends, of course, on type of component which is the source of the irreversibilities.




Figure 5. Exergy destruction as a percentage of total exergy destruction for all components in proposed cogeneration system at ISO condition.

Figure 5 shows the exergy destruction rate for each component as a percentage of total exergy destruction for all components in the system. The highest source of irreversibilities occurs in the combustion chamber due to turbulent mixing, chemical reactions, friction and heat loss. The exergy destruction in the combustor is about 60%, higher than all the other components combined. This value can be reduced by preheating the fuel or compressed air and reducing excess air to near the stoichiometric value. Improving the mixing may also help to increase combustion efficiency.

The RO unit constitutes the second source of irreversibilities of 14.8%, which is relatively high compared to the exergy fuel input. This high level of waste exergy is attributed to friction, leakage losses and the large number of components in the RO unit. The LPT was third in the level of exergy destruction. It has a higher number of stages than either HPT or IPT; even the blade size creates more exergy destruction due to friction. The intercooler is next at 5.5%, due to heat losses, temperature differences and friction. The effect of friction and aerodynamic loss predominate in the HPC component. The high fuel exergy and expansion rate are the main causes of irreversibilities within HPT. The LPC and IPT have lowest exergy destruction because both of them are mechanically coupled with a low rate of compression and expansion with respect to other rotating parts.




Figure 6. Relative exergy destruction as a percentage for the main RO unit components.

Figure 6 illustrates the relative percentages of total exergy destruction for the main components in the RO unit. The highest exergy destruction occur in the pumps (41%) followed by the first membrane modules (30%), then the second membrane modules and Pressure Exchanger-PX (both at 12%). The high pressure pumps in SWRO (HHP) and BWRO (HBP), represent over 76 % of pump exergy destruction. That can be reduced by using more efficient pumps. The

high exergy destruction in the membrane modules may be attributed to fouling, hydraulic resistance and concentration polarization, thus improved membrane design could significantly enhance RO performance. The main sources of irreversibilities in the PX are friction and mixing. The membrane modules and PX have the same percentage of exergy destruction, but the latter has more potential for reducing both energy consumption and cost. In the current model the Shuwaikh RO plant used a PX, so there is a high potential for improvement using the more advanced isobaric, or pressure-equalising ERD.




Figure 7. Relative exergy destructions for different loads for proposed cogeneration system under ISO conditions.

The effect of load variation on exergy destruction for all plant component is shown in Figure 7. The load variations are controlled mainly by electrical grid demand, which will vary during the day and with the season. The range shown is between minimum safe load (50%) and full load, at design conditions. These two limit may change slightly with off-design conditions. In general, the highest exergetic efficiency is achieved at full load, but exergy destruction with load varies according to the component being considered. The exergy destruction in the combustion chamber decreases as the load decreases due to a reduction in the rate of fuel

consumption. The proportional reduction in heat input is lower than power output, which explains the reduction in exergetic efficiency as the load decreases.

The expansion rate in the power turbine (LPT) reduced with load reduction and that caused a drop in exergy destruction level. The HPT and IPT have the same trend as HPC and IPC due to the mechanical coupling between them. Reducing the load increases exergy destruction because the fuel exergy relative to the expansion rate is increased. The intercooler in the ICGT has a higher irreversibilities level because the fall in exergy destruction rate is less than the total value of exergy destruction.

The relation between power to water ratio and exergetic efficiency is directly proportional. The exergy destruction in the RO unit with respect to total exergy destruction increases at part load whereas it registered the minimum value at full load.

In accord with the above results it is highly recommended to always operate the GT at full load, and the cogeneration system at high power to water ratio.




Figure 8. Exergetic efficiency versus and ambient temperatures for ICGT-RO cogeneration plant.

The exergetic efficiency of a cogeneration plant varies with ambient temperature, see Figure 8. The variation in ambient temperatures is considered a good indicator of climate change. The effect of ambient temperature on plant performance was reduced due to the presence of intercooling. Ambient temperature effects are confined to LPC components, due particularly to increasing power consumption to compensate for the decrease in air density with increase in ambient temperature. Rising ambient temperature lead to a reduction in exergetic efficiency and the relation between them is inversely proportional. The exergy destruction in the LPC increases because of increasing fuel exergy in order to compensate for change in air density.




Figure 9. Exergetic efficiency versus and pressure ratio for ICGT-RO cogeneration plant.

Figure 9 shows the effect of variation of pressure ratio on plant performance. The exergetic efficiency of the cogeneration plant rose as the pressure ratio increased due to the increase in temperature of the compressed air temperature entering the combustion chamber. Hence, the amount of fuel required to meet the high-pressure turbine requirements decreased. The energy consumed by the compressors was less than the energy saved by the reduction in fuel

consumption and that raised the exergetic efficiency as the pressure ratio increased. The ICGT has the highest pressure ratio as well as efficiency among all aeroderivative GT engines used for power generation today. Designing and/or operating the compressor at a high-pressure ratio will be beneficial from a performance perspective.




Figure 10. Exergetic efficiency and minimum work of separation versus feed temperature.

The sea water feed temperature significantly effect on RO unit performance as shown in Figure 10. It is well know that the sea water temperature in the Arabian Gulf varies from 10°C to 32°C with seasonal changes. This fact confirms the importance of investigating feed temperature either in the design or operational stages. The exergetic efficiency of the RO unit increased as feed temperature increased due to reduction in fuel exergy input and increasing minimum work of separation. Increase in feed temperature from 15°C to 28°C increased RO unit exergetic efficiency uniformly by 2.26%, this was due largely to the increased value of minimum work of separation. Such a result strongly supports the hybridization of RO plant with thermal desalination or steam power plants in order to provide high temperature feed water. The

exergetic efficiency of the cogeneration plant remained almost constant because the amount of energy saved in the RO unit was so small compared to the total energy consumed by the plant as a whole.

Figure 11 shows the environmental impact of the proposed system at the different operating conditions. The ICGT can be subject to part load due to variations in electrical network demand, which are based on the end users' requirement. The relation between load variation as a percentage and exergetic environmental efficiency is shown in Figure 11A. Generally, as the load reduces, the exergetic environmental efficiency reduces and the relation between them is directly proportional. Therefore, it is highly recommended to operate the system at full load to achieve best performance as well as low emission per MWh.

Figure 11B shows that CO₂ intensity increases with increase in ambient temperature. That may be attributed to the level of reduction in net power output being greater than the fuel reduction. The reduction in net power output results from the increase in the compressor's power consumption due to the decrease in air density. Thus, the net power output will reduce as ambient temperature rises. The reduction in fuel consumption is mainly due to raising the compressed air temperature at the exit of high-pressure compressor.

The system's environmental impact is more sensitive to load variation than ambient temperature change due to the intercooling effect and the cogeneration system is more environmentally favourable in comparison with ICGT standalone.




Figure 11 :Environmental impact for ICGT and cogeneration plant A) Exergetic-environmental efficiency and B) CO₂ intensity.

5- Conclusion

This work presents an energetic and exergetic analysis of cogeneration plant based on an ICGT and a large RO desalination unit. The IPSEpro software was used for modelling and analyzing the proposed system. The most recently published data were used to evaluate the thermophysical properties of seawater treating it as a real mixture. The extracted exergetic data shows good agreement with the manufacturer's data and recent studies presented in Mistry et al. (2011) and Kempton et al. (2010).

The analysis confirmed that the combustion chamber has the highest level of irreversibilities followed by the RO unit and LPT, representing over 82.7 % of total exergy destruction. The high-pressure pump, membrane modules and ERD are the main causes of exergy loss in the RO unit. The exergetic efficiency of a cogeneration plant is about 47.6 % with advantages of high performance for separated systems and a shorter installation period than other systems for power and water generation.

It has been demonstrated that exergetic efficiency increased as the load and pressure ratio increased; the relation between them is directly proportional. Rising feed water temperature, significantly improved RO unit efficiency but, as a whole, the cogeneration plant was almost

unaffected. Enhancement of the ICGT engine performance contributes much more than improving the desalination unit to cogeneration plant performance, a high electrical power to water ratio always recommended. Maintaining a full load on the ICGT is important for good plant performance. The intercooled system reduces or limits the ambient temperature effect on the system and low values are more favourable. The cogeneration proposed system is considered more sustainable with respect to separated systems.

Acknowledgments

The authors wish to thank the Ministry of Electricity and Water in Kuwait for its assistance and support in the current work.

Reference

- Ahrendts, J. (1980). "Reference State." *Energy*, 5, 667–677.
- Aljundi, I. H. (2009). "Second-Law Analysis of a Reverse Osmosis Plant in Jordan." *Desalination*, 239(1-3), 207–215.
- Almutairi, A., Pericles, P., and Al-Mutawa, N. (2015a). "Exergetic and Environmental Analysis of 100 MW Intercooled Gas Turbine Engine." 7th International Exergy, Energy and Environment Symposium, Valenciennes – France.
- Almutairi, A., Pilidis, P., and Al-Mutawa, N. (2015b). "Energetic and Exergetic Analysis of Combined Cycle Power Plant: Part-1 Operation and Performance." *Energies*, 8(12), 14118–14135.
- Al-Sulaiman, F., Hamdullahpur, F., and Dincer, I. (2011). "Performance Comparison of Three Trigeration Systems Using Organic Rankine Cycles." *Energy*, 36(9), 5741–5754.
- Al-Weshahi, M., Anderson, A., Tian, G., and Makhdoum, B. (2013). "Validation of Simulation Model for Cogeneration Power and Water Desalination Plant." *International Journal of Modeling and Optimization*, 3(1), 46–51.
- Al-Zahrani, a., Orfi, J., Al-Suhaibani, Z., Salim, B., and Al-Ansary, H. (2012). "Thermodynamic Analysis of a Reverse Osmosis Desalination Unit with Energy Recovery System." *Procedia Engineering*, 33, 404–414.
- Aydin, H. (2013). "Exergetic Sustainability Analysis of LM6000 Gas Turbine Power Plant with Steam Cycle." *Energy*, 57, 766–774.
- Bejan, A., Tsatsaronis, G., and Michael, M. (1996). "Thermal Design and Optimization." John Wiley & Sons.
- Cerci, Y. (2002). "Exergy Analysis of a Reverse Osmosis Desalination Plant in California." *Desalination*, 142(3), 257–266.
- Cooper, J. R., and Dooley, D. R. (2007). "The International Association for the Properties of Water and Steam. Revised Release on the IAPWS Industrial Formulation 1997 for the Thermodynamic Properties of Water and Steam" Technical Report, [Online], Available: www.iapws.org.

- Culkin, F., and Ridout, P. S. (1998). "Stability of IAPSO Standard Seawater." *Journal of Atmospheric and Oceanic Technology*, 15(4), 1072-1075.
- Darwish, M. A. (2014). "Thermal Desalination in GCC and Possible Development." *Desalination and Water Treatment*, 52(1-3), 27-47.
- Dashtpour, R., & Al-zubaidy, S. N. (2012). "Energy Efficient Reverse Osmosis Desalination Process." *International Journal of Environmental Science and Development*, 3(4), 339-345.
- Dincer, I., and Rosen, M. A. (2013). "Exergy, Energy, Environment and Sustainable Development." Elsevier Ltd.
- El-Emam, R. S., and Dincer, I. (2014). "Thermodynamic and Thermo-economic Analyses of Seawater Reverse Osmosis Desalination Plant with Energy Recovery." *Energy*, 64, 154-163.
- Farooque, A. M., Jamaluddin, A. T. M., Al-Reweli, A. R., Jalaluddin, P. A. M., Al-Marwani, S. M., Al-Mobayed, A. A., and Qasim, A. H. (2008). "Parametric Analyses of Energy Consumption and Losses in SWCC SWRO Plants Utilizing Energy Recovery Devices." *Desalination*, 219(1-3), 137-159.
- Hepbasli, A. (2008). "A Key Review on Exergetic Analysis and Assessment of Renewable Energy Resources for a Sustainable Future." *Renewable and Sustainable Energy Reviews*, 12(3), 593-661.
- Hou, S., Zeng, D., Ye, S., and Zhang, H. (2007). "Exergy Analysis of the Solar Multi-Effect Humidification-Dehumidification Desalination Process." *Desalination*, 203(1-3), 403-409.
- Kahraman, N., and Cengel, Y. (2005). "Exergy Analysis of a MSF Distillation Plant." *Energy Conversion and Management*, 46(15-16), 2625-2636.
- Kempton, R., Maccioni, D., Mrayed, S. M., and Leslie, G. (2010). "Thermodynamic Efficiencies and GHG Emissions of Alternative Desalination Processes." *Water Science and Technology: Water Supply*, 10(3), 416-427.
- Khaliq, A. (2015). "Energetic and Exergetic Performance Evaluation of a Gas Turbine-Powered Cogeneration System Using Reverse Brayton Refrigeration Cycle for Inlet Air Cooling." *Journal of Energy Engineering*, 10.1061/(ASCE)EY.1943-7897.0000290, 04015029.
- MEW (Ministry of Electricity and Water - State of Kuwait) (2008). "Shuwaikh RO Desalination Plant Technical Specification."
- Midilli, A., and Dincer, I. (2009). "Development of Some Exergetic Parameters for PEM Fuel Cells for Measuring Environmental Impact and Sustainability." *International Journal of Hydrogen Energy*, 34(9), 3858-3872.
- Mistry, K. H., McGovern, R. K., Thiel, G. P., Summers, E. K., Zubair, S. M., and Lienhard V, J. H. (2011). "Entropy Generation Analysis of Desalination Technologies." *Entropy*, 13(12), 1829-1864.
- Querol, E., Gonzalez-Reguer, B., and Perez-Benedito, J. L. (2012). "Practical Approach to Exergy and Thermo-economic Analyses of Industrial Processes." Springer Science and Business Media.
- Romero-Ternero, V., García-Rodríguez, L., and Gómez, C. (2005). "Exergy Analysis of a Seawater Reverse Osmosis Plant." *Desalination*, 175, 197-207.
- Sharqawy, M. H., Lienhard, J. H., and Zubair, S. M. (2010). "On Exergy Calculations of Seawater with Applications in Desalination Systems." *International Journal of Thermal Sciences*, 50(2), 187-196.
- Sharqawy, M. H., Lienhard, J. H., and Zubair, S. M. (2011a). "Thermophysical Properties of Seawater: A Review of Existing Correlations and Data." *Desalination and Water Treatment*, 16 (1-3), 354-380.
- Sharqawy, M. H., Zubair, S. M., and Lienhard, J. H. (2011b). "Second Law Analysis of Reverse Osmosis Desalination Plants: An Alternative Design Using Pressure Retarded Osmosis." *Energy*, 36(11), 6617-6626.
- Wang, X., and Tang, Y. (2013). "Exergetic Analysis on the Two-Stage Reverse Osmosis Seawater Desalination System." *Desalination and Water Treatment*, 51(13-15), 2862-2870.

Nomenclature

B	Brine water flow rate
D	Distillate water flow rate
\dot{E}	Rate of exergy flow in stream
\bar{e}_k^{ch}	Specific molar chemical exergy
F	Feed water flow rate
g	Acceleration of gravity
h	Specific enthalpy
h_{fg}	Latent heat of vaporization
$\overline{\text{LHV}}$	Low heating value in molar basis
M	Cooling seawater flow rate
\dot{m}	Mass flow rate
\dot{n}	Number of mole rate
P	Pressure of the stream
\dot{Q}	Heat transfer rate
R	Gas constant
\bar{R}	Universal gas constant
s	Specific entropy
\dot{S}	Entropy generation
T	Temperature of the stream
y	Mole fraction
V	Specific volume
\dot{w}	Power
\dot{w}_{min}	Minimum work of separation

Greek letters

$\bar{\lambda}$	Fuel to air ratio in molar bases
η_{ex}	Exergetic Efficiency
μ_k	chemical potential
ξ_{CO_2}	Exergetic–environmental efficiency
φ_{ac}	Actual mass of CO ₂ per MWh
φ_{st}	Stoichiometric mass of CO ₂ per MWh
φ_{cogen}	CO ₂ intensity for cogeneration plant

Subscripts

ac	Actual
c	Cold Stream
ch	Chemical
cv	Control volume
d	Destruction
e	Outlet
f	Fuel
h	Hot Stream
i	Inlet
k	Component
ke	Kinetic energy
l	Loss
m	motive steam
o	Reference state
p	Product
ph	Physical
pe	Potentials
r	Entrained vapor
S	Steam
x	Total

Abbreviations

AFR	Air to fuel ratio
AC	Air compressor
CC	Combustion chamber
CO ₂	Carbon Dioxide
DAF	Dissolved air flotation
EBP	ERD booster pump
ERD	Energy recovery device
FFP	filter feed pump
GE	General Electric
GT	Gas Turbine
HBP	high-pressure brackish pump
HPC	High-Pressure compressor
HPP	high-pressure pump
HPT	High-Pressure turbine
ICGT	Intercooled gas turbine
IP	Intermediate-Pressure turbine
ISO	International Standards Organization
LP	Low-Pressure turbine
MED	Multi-effect desalination
MEW	Ministry of Electricity and Water
MSF	Multi Stage Flash
PEM	Polymer electrolyte membrane
PWP	Product water pump
PX	Pressure exchange
RO	Reverse osmosis
SSP	seawater supply pump
UF	Ultrafiltration
UFP	Ultrafiltration pump
WWP	Waste Water pump

Appendix A - Validation of Proposed Models

In Appendix-A, the validation of the intercooled gas turbine engine LMS 100 and Al Shuwaikh RO desalination plant models with manufacturer data as illustrated in tables A-1 and A-2.

Table A-1: LMS100 published performance data with result of equivalent proposed model.

Description	GE	IPSEpro Model	Unit
Power output (MW)	98.70	98.80	MW
Thermal efficiency (%)	45.00	43.30	%
Heat rate (KJ/KWh)	7921.00	8307.53	KJ/KWh
Pressure ratio	42.00	42.00	----
Exhaust Mass flow (Kg/s)	222.00	222.00	Kg/s
Exhaust Temperature (K)	685.00	689.00	K

Table A-2: The validation of AL-Shuwaikh RO Desalination Plant.

Description	Doosan	IPSEpro Model	Unit
Number of SWRO stages	10	10	----
Number of BWRO nit stages	4	4	----
Seawater feed temperature	15	15	°C
Seawater temperature salinity	45000	45000	ppm
Design mass flow rate	4921.1	4921.1	Kg/s
Permeate mass flow rate	1611.1	1611.1	Kg/s
Rejected mass flow rate	3342.8	3342.8	Kg/s
SWRO permeate mass flow rate	1750	1750	Kg/s
SWRO bypass permeate mass flow rate	361.1	361.1	Kg/s
SWRO permeate mass flow rate	1250	1250	Kg/s
BWRO rejected mass flow rate	138.8	138.8	Kg/s
Permeate salinity	less than 200	less than 200	ppm
Brine salinity	66279	66279	ppm
SSP discharge pressure	2.5	2.5	bar
FFP discharge pressure	5.5	5.5	bar
UF Backwash discharge pressure	4.5	4.5	bar
ERD booster pump discharge pressure	66.7	66.7	bar
SWRO HPP discharge pressure	66.7	66.7	bar
BWRO HPP discharge pressure	13.7	13.7	bar
SWRO recovery ratio	42	42	%
BWRO recovery ratio	90	90	%

Appendix B - Seawater Thermo-Physical Properties

The thermophysical properties of seawater were determined by using a model of International Association for the Physical Sciences of the Oceans (IAPSO) (Culkin and Ridout,1998). The Gibbs energy in proposed model is a function of pressure, temperature and salinity and used to calculate thermodynamic properties. The fundamental equations details shown in 2008 issued by International Association of Properties of Water and Steam (IAPWS) (Cooper and Dooley , 2007). Sharqawy et al. (2010) proposed some correlations to calculate specific volume, specific enthalpy, specific entropy and chemical potential. These correlations validated with IAPSO and IAPWS models and showed good agreement. Table B-1 shows some constants that used to calculate thermodynamic properties.

Table B-1: Thermodynamical empirical correlation constants.

a ₁	b ₁	b ₆	c ₁	c ₆
8.02x10 ²	-2.348x10 ⁴	-4.417x10 ¹	-4.231x10 ²	-1.443x10 ⁻¹
a ₂	b ₂	b ₇	c ₂	c ₇
-2.001x10 ¹	3.152x10 ⁵	2.139x10 ⁻¹	1.463x10 ⁴	5.879x10 ⁻⁴
a ₃	b ₃	b ₈	c ₃	c ₈
1.677x10 ⁻²	2.803x10 ⁶	-1.991x10 ⁴	-9.88x10 ⁴	-6.111x10 ¹
a ₄	b ₄	b ₉	c ₄	c ₉
-3.06x10 ⁻⁵	-1.446x10 ⁷	b2.778x10 ⁴	3.095x10 ⁵	8.041x10 ¹
a ₅	b ₅	b ₁₀	c ₅	c ₁₀
-1.613x10 ⁻	7.826x10 ³	9.728x10 ¹	2.562x10 ¹	3.035x10 ⁻¹

The following equations give the specific volume (v), specific enthalpy (h) and specific entropy (s) colorations:-

$$v_{sw} = \frac{1}{\rho_{sw}} \quad (B-1)$$

$$\rho_{sw} = \rho_w + w_s(a_1 + a_2T + a_3T^2 + a_4T^3 + a_5w_sT^2) \quad (B-2)$$

$$\rho_w = 9.999x10^2 + 2.034x10^{-2}T - 6.162x10^{-3}T^2 + 2.261x10^{-5}T^3 - 4.657x10^{-8}T^4 \quad (B-3)$$

$$h_{sw} = h_w - w_s(b_1 + b_2w_s + b_3w_s^2 + b_4w_s^3 + b_5T + b_6T^2 + b_7T^3 + b_8w_sT + b_9w_s^2T + b_{10}w_sT^2) \quad (B-4)$$

$$h_w = 141.355 + 4202.070 T - 0.535 T^2 + 0.004T^3 \quad (B-5)$$

$$s_{sw} = s_w - w_s(c_1 + c_2w_s + c_3w_s^2 + c_4w_s^3 + c_5T + c_6T^2 + c_7T^3 + c_8w_sT + c_9w_s^2T + c_{10}w_sT^2) \quad (B-6)$$

$$s_w = 0.1543 + 15.383 T - 2.996 \times 10^{-2} T^2 + 8.193 \times 10^{-5} T^3 - 1.37 \times 10^{-7} T^4 \quad (B-7)$$

Where the subscripts (w) and (sw) represent pure water and saline water. The salt concentration symbolized by w_s in $\text{kg}_s/\text{kg}_{sw}$. The temperature unit in all above equation should be in Celsius and the outcome unit for the specific volume, specific enthalpy and specific entropy will be m^3/kg , J/kg and $\text{J}/(\text{kg}\cdot\text{k})$.

The chemical potentials of seawater can be calculated from the derivative of Gibbs energy function as shown in the following equations:-

$$\mu_w = \frac{\partial G_{sw}}{\partial m_w} = g_{sw} - w_s \frac{\partial g_{sw}}{\partial w_s} \quad (B-8)$$

$$\mu_s = \frac{\partial G_{sw}}{\partial m_s} = g_{sw} + (1 - w_s) \frac{\partial g_{sw}}{\partial w_s} \quad (B-9)$$

$$g_{sw} = h_{sw} - (T + 273.15)s_{sw} \quad (B-10)$$

$$\frac{\partial g_{sw}}{\partial w_s} = \frac{\partial h_{sw}}{\partial w_s} - (T + 273.15) \frac{\partial s_{sw}}{\partial w_s} \quad (B-11)$$

$$-\frac{\partial h_{sw}}{\partial w_s} = b_1 + 2b_2w_s + 3b_3w_s^2 + 4b_4w_s^3 + b_5T + b_6T^2 + b_7T^3 + 2b_8w_sT + 3b_9w_s^2T + 2b_{10}w_sT^2 \quad (B-12)$$

$$-\frac{\partial s_{sw}}{\partial w_s} = c_1 + 2c_2w_s + 3c_3w_s^2 + 4c_4w_s^3 + c_5T + c_6T^2 + c_7T^3 + 2c_8w_sT + 3c_9w_s^2T + 4c_{10}w_sT^2 \quad (B-13)$$

Where g_{sw} is the specific Gibbs energy of seawater.

Appendix C - Molar and Energy Analysis

The fuel mass flow rate in ICGT engine vary with a change in operating conditions. The compressed air temperature inlet to annular combustor significantly effect on the air to fuel ratio (AFR). The ICGT can be operated by using natural gas or liquid fuel. In the current study, the former were used the following composition.

Table C-1. Natural gas components molar fraction.

Component	Molar fraction (%)
Methane (CH ₄)	93.34
Ethane (C ₂ H ₆)	0.211
Propane (C ₃ H ₈)	0.029
Nitrogen (N ₂)	6.42

The air stream composition in the in the cold section is given in Table C-2.

Table C-2. Air components molar fraction.

Component	Molar fraction (%)
Nitrogen (N ₂)	77.48
Oxygen (O ₂)	20.59
Water (H ₂ O)	1.9
Carbon dioxide (CO ₂)	0.03


The stoichiometric AFR value were determined by applying Molar analyses as explained (Bejan et al. , 1996). The molar air to fuel is given by:

$$\frac{1}{\bar{\lambda}} = \frac{\dot{n}_a}{\dot{n}_f} \quad (\text{C-1})$$

Where \dot{n} and $\bar{\lambda}$ refer to rate of number of mole and fuel-to-air ratio. Where \dot{n} and $\bar{\lambda}$ refer to the rate of a number of moles and fuel-to-air ratio. The subscripts (a) and (f) represent air and fuel respectively. The rate of number of moles defined as a ratio of mass flow rate to molecular weight and can be expressed by:

$$\dot{n} = \frac{\dot{m}}{M} \quad (C-2)$$

The combustion reaction for case study can be written in term of mole fractions (y) and takes the following form:



The air to fuel ratio can be calculated by using energy balance equation between fuel and difference in enthalpies due to heat addition. The reactant and product enthalpies were determined by applying ideal gas mixture principles on combustor chamber upstream and downstream conditions. The energy rate equation for ICGT rotating components under adiabatic condition is given by:

$$\text{Compressor: } \dot{W}_{Ac} = \dot{m}_a (h_e - h_i) \quad (C-4)$$

$$\text{Gas Turbine: } \dot{W}_{GT} = \dot{m}_p (h_i - h_e) \quad (C-5)$$

The rate of heat transfer in the combustor can be calculated from molar low heating value of natural gas with assuming 2% as a heat loss using the following expression:

$$\dot{Q}_{cv} = -0.02 \dot{n}_f \overline{LHV} = \dot{n}_a (-0.02 \bar{\lambda}) \overline{LHV} \quad (C-6)$$

The energy balance equations for the adiabatic pumps are given by:

$$\text{Pump} \quad : \dot{W}_p = \dot{m}_w (h_e - h_i) \quad (C-7)$$

Exergetic and sustainability analysis of an intercooled gas turbine cogeneration plant with reverse osmosis desalination system

Almutairi, Abdulrahman

2017-03-14

Attribution-NonCommercial 4.0 International

Almutairi A, Pilidis P, Al-Mutawa N, Al-Weshahi M. (2017) Exergetic and sustainability analysis of an intercooled gas turbine cogeneration plant with reverse osmosis desalination system, *Journal of Energy Engineering*, Volume 143, Issue 5, October 2017, Article number 04017016
[http://dx.doi.org/10.1061/\(ASCE\)EY.1943-7897.0000445](http://dx.doi.org/10.1061/(ASCE)EY.1943-7897.0000445)

Downloaded from CERES Research Repository, Cranfield University